

THE TAMIL NADU PUBLIC BUILDINGS (LICENSING) RULES, 1966

THE SCHEDULE - FORM - A

[Form of application under sub-section (1) / sub-section (2) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) referred to in rules 3 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966]

From

The Correspondent ,  
M/s.SRV Public School,  
Lord Sri Venkateshwara Educational Trust,  
T.S.no: 30/3,30/2B2,29/5, Wrd- B, Block-1,  
Jahir Hussain salai, Salem road, Rasipuram  
municipal limit,Namakkal ( Dt).

To

The Tahsildar,  
Taluk Office,  
Rasipuram.

Sir


1. I intend / to use the building / to continue to use the existing building / to use the existing building not at present used as a public building /which is situated in the site or plot of land T.S.no: 30/3,30/2B2,29/5 Town (or) Revenue Street or Road in the village / Rasipuram taluk / Namakkal district and specified in the Statement enclosed, as a public building for a period of Three years from the 01.06.2021 to 31.05.2024.

2. The year of construction and the present approximate cost of construction and the purpose for which it is to be used or is being used as Public building are also furnished in the statement accompanying this application.

3. I enclose a challan for Rs .....

4. I also enclose a certificate of structural soundness in the prescribed form furnished by the Engineer Mr.N.Manickam,B.E.,M.I.E.,F.I.V. Registration No: 24740/2007/C2 Class IA of Namakkal Collectorate.

Date : .....



Signature of the Owner of the Building

Secretary & Correspondent  
SRV PUBLIC SCHOOL (CBSE)  
Salem Main Road,  
RASIPURAM - 637 408, Namakkal DL

Enclosures:

- (1) Statement
- (2) Challan for Rs ..... towards the application fee

1/11


**STATEMENT ACCOMPANYING FORM A**

1	S.F.No ( or ) Door Number of Building:	T.S.no: 30/3,30/2B2,29/5				
2	Location :	Located in Rasipuram Municipal limit, abutting Salem Main road				
	Name of building :	T.S.no: 30/3,30/2B2,29/5, SRV Public School, Jahir Hussain salai, Salem road, Rasipuram municipal limit, Namakkal ( Dt).				
	Corporation/ Municipality /Panchayat/ Panchayat Union /Township/Cantonment	Rasipuram municipal limit				
3	Year of Construction	Given in statement				
4	Approximate cost of construction as per current rates:	Given in statement				
S. No	Name of building with Description Details.	Area of building	Year of construction	Future age of building	Cost of building	Floor area of Class rooms
1.	<b><u>Main Block-Ground floor :</u></b>					
a.	Foundation & Basement: R.c.c.Pillar, beams & base with p.c.c. brick work in c.m. R.c.c roof. Wooden Doors & windows: Alumini frames with glazed shutters, Flooring with p.c.c. and floor finish with tiles. Wiring : Consealed	15146.25 sqft (or) 1407.13 sqm	2007 age 14 years	46 years	1,00,00,000/-	6.71M x 6.93M x7
b.	<b><u>First floor :</u></b> Superstructure: R.c.c.Pillars, beams and brick work in cement mortar. R.c.c roof. Wooden Doors & windows: Alumini frames with glazed shutters, floor finish with cement mortar.	14865.69 sqft (or) 1381.06 sqm	2007 age 14 years	46 years	95,00,000/-	6.71M x 6.93M x10
c.	<b><u>Second floor :</u></b> Superstructure: R.c.c. Pillars, beams and brick work in cement mortar. R.c.c roof. Wooden Doors & windows: Alumini frames with glazed shutters, floor finish with cement mortar	14865.69 sqft (or) 1381.06 sqm	2007 age 14 years	46 years	1,00,00,000/-	At present as room, in future it will be altered for class rooms, hall and staff rooms.
d.	<b><u>Head room :</u></b>	378.12 sqft (or) 35.14 sqm	2007 age 14 years	46 years	1,60,000/-	



5	Purpose for which the building is being used or proposed to be used	Being used for School purpose
6	Purpose for which the building has hitherto been used	School purpose
7	Details of Construction of the Buildings (particulars of the foundation soil, specifications of the various parts under)	R.C.C framed Structure
	(1) Foundation	: R.C.C pillars & beams, brick work in cement mortar & Plastering with c.m
	(2) Basement	: Gravel filling, Sand filling & flooring with p.c.c
	(3) Superstructure	: Brick work in c.m & plastering with c.m
	(4) Floor	: Flooring with P.C.C and Floor finish with cement mortar & Tiles
	(5) Roof	R.C.C roof
	(6) Doors and Windows	: Wooden Doors and Aluminium frame windows with glazed shutters
	(7) Electrical	: Consealed wiring with P.v.c pipes, wires & fittings.
	(8) Plumbing	: P v c pipes, outer area pipes and inner area with open works
	(9) Painting	Walls: Inside with primer & distemper, Outside with Primer & distemper
8	Period for which licence is required	Three years - 01.06.2021 to 31.05.2024
9	Number of persons to be accommodated	Students : 700 nos Staff : 30+5 nos

Date: 04.05.2021

  
Signature of the Engineer

**N.MANICKAM, B.E., MIE., PIV.,**  
Chartered Civil Engineer / Valuer  
District Panel Engineer - Class I A  
Approved Valuer for Banks  
05, C.P. Kennalah Street  
Rasipuram - 637 408, Namakkal (Dt)  
Cell - 98427 34137

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh licence in case any addition or alteration is made to the existing building or portion of building. I also undertake to obtain a fresh licence if the purpose for which the licence was granted for the use of the building or a portion of the building originally is changed or altered subsequently

Date:

  
Signature of the owner of the building

Secretary & Correspondent  
**SRV PUBLIC SCHOOL (CBSE)**  
Salem Main Road,  
**RASIPURAM - 637 408, Namakkal Dt.**

3/11

## FORM - B

(Form of certificate of structural Soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965

(Tamil Nadu Act XIII of 1965) referred in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features:

(1)	Foundation:-	<u>R.C.C Framed structure</u>
	(i) Depth below Ground level	3.05-3.60 m
	(ii) Nature of soil met with at foundation level	Hard Gravel
	(iii) Pressure at foundation	25-26 t/sqm
	(iv) Probable safe bearing capacity of the strata met with at foundation	35 t/sqm
(2)	Superstructure	
	(i) Maximum stress in the most critical section of masonry and concrete	30 t/sqm
	(ii) Nature of masonry and concrete and its safe permissible stress.	Brick masonry - 50t/sqm R.C.C:440 t/sqm

The structural soundness of the building has been verified by me with reference to I.S.I loading standards 875 (Latest version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from the 01.06.2021 to the 31.05.2024 inclusive...

Date: 04.05.2021

Signature of the Engineer

**N.MANICKAM** B.E,MIE,PIV.,  
DIST. PANEL ENGINEER CLASS - 1A  
(Reg No. 24740/2007/C2 dt 01.08.2007 Collectorate, Namakkal)  
Chartered Civil Engineer & Valuer  
66 C.P.Kannaiah street,  
Rasipuram - 637408, Namakkal.

4/11



**STATEMENT TO ACCOMPANY  
THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

Location of the building - Door Number, Street and name of the place	Age of Building	The value of the Building at the current rates	Number of storeys	Short description of structures - Steel - RCC framed or load bearing masonry	Purpose for which the building is certified for use	The period for which the building will be structurally sound	Number of persons to be accommodated	Remarks
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
SRV Public School, T.S.No: 30/3,30/2B2, 29/5 Jahir Hussain salai, Salen road, Rasipuram, Namakkal ( Dt).  Area of building:  1. Main Block: (i) Ground floor = 1407.13 sqm (ii) First floor = 1381.06 sqm (iii) Second floor = 1381.06 sqm (iv) Head room = 35.14	2007/14yrs	1,00,00,000/-	G+2	R.C.C framed structure	School purpose	Three years (01.06.2021 to 31.05.2024)	School: Students : 700 nos Staffs : 30+5 nos	

*N. Manickam*  
4/5/24  
Signature of the Engineer

**N.MANICKAM** B.E,MIE,FIV.,  
DIST. PANEL ENGINEER CLASS - IA  
(Reg No. 24740/2007/C2 dt 01.08.2007 Collectorate, Namakkal)  
Chartered Civil Engineer & Valuer  
66 C.P.Kannaiah street,  
Rasipuram - 637408, Namakkal.

711

**FORM - C**

(Form of certificate of structural Soundness under sub-section (4) of section 4 of the Tamil Nadu Public Buildings (Licensing) Act, 1965


(Tamil Nadu Act XIII of 1965) referred to in rule 4 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)

I certify that I have inspected the buildings mentioned in the statement and furnish below its salient technical features:

(1)	Foundation:-	<u>R.C.C Framed structure</u>
(i)	Depth below Ground level	3.05-3.60 m
(ii)	Nature of soil met with at foundation level	Hard gravel
(iii)	Pressure at foundation	25-26 t/sqm
(iv)	Probable safe bearing capacity of the strata met with at foundation	35 t/sqm
(2)	Superstructure	
(i)	Maximum stress in the most critical section of masonry and concrete	30 t/sqm
(ii)	Nature of masonry and concrete and its safe permissible stress.	Brick masonry – 50t/sqm R.C.C:440 t/sqm

The structural soundness of the building has been verified by me with reference to I.S.I loading standards 875 (Latest version) and other relevant Indian Standards Code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be granted for the period from the 01.06.2021 to the 31.05.2024 inclusive...

Date: 04.05.2021

  
Signature of the Engineer  
N.MANICKAM, B.E., MIE., FIV.,  
Chartered Civil Engineer / Valuer  
District Panel Engineer - Class I A  
Approved Valuer for Banks  
66, C.P. Kannaiah Street  
Reipuram - 637 408, Namakkal (Dt)  
Cell - 98427 34127

**Designation**

- i) LICENSED BUILDING SURVEYOR
- ii) CHARTERED CIVIL ENGINEER
- iii) STRUCTURAL ENGINEER
- iv) DISTRICT PANEL ENGINEER CLASS - IA
- v) REGISTERED VALUER

5/11

**STATEMENT TO ACCOMPANY  
THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

Location of the building - Door Number, Street and name of the place	Age of Building	The value of the Building at the current rates	Number of storeys	Short description of structures - Steel - RCC framed or load bearing masonry	Purpose for which the building is certified for use	The period for which the building will be structurally sound	Number of persons to be accommodated	Remarks
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
SRV Public School, T.S.No: 30/3,30/282, 29/5 Jahir Hussain salai, Saler's road, Rasipuram, Namakkal ( Dt).								
Area of building:								
1. Main Block:								
(i) Ground floor = 1407.13 sqm	2007/14yrs	1,00,00,000/-	G+2	R.C.C framed structure	School purpose	Three years (01.06.2021 to 31.05.2024)	School: Students : 700 nos Staffs : 30+5 nos	---
(ii) First floor = 1381.06 sqm	2007/14yrs	95,00,000/-						
(iii) Second floor = 1381.06 sqm	2007/14yrs	1,00,00,000/-						
(iv) Head room = 35.14	2007/14yrs	1,60,000/-						

*N. Manickam*  
41574

Signature of the Engineer

**N.MANICKAM R.E,MIE,FIV.,**  
DIST. PANEL ENGINEER CLASS - IA  
(Reg No. 24740/2007/C2 dt 01.08.2007 Collectorate, Namakkal)  
Chartered Civil Engineer & Valuer  
66 C.P.Kannaiah street,  
Rasipuram - 637408, Namakkal.

7/11



FORM D

DECLARATION

1. N. Manickam, S/o. Nallathambi Udayar, 66N C.P.Kanniah street, Rasipuram – 637 408. do hereby declare that I possess the qualification and experience specified in the Table to rule II of Madras public buildings (Licensing) Rules, 1966 for issuing the certificate of structural soundness of the building covered by the certificate.

Stations : Rasipuram

Dated : 04.05.2021

  
415724  
N. MANICKAM, B.E., MIE., FIV.  
N. MANICKAM, B.E., MIE., FIV.  
Chartered Civil Engineer / Valuer  
District Panel Engineer - Class 1A  
Approved Valuer for Banks  
66, C.P. Kanniah Street  
Rasipuram - 637 408, No. Sakral (OU)  
Cell : 9942734117

Name and Address ( In Block Letters)

: Mr. N. MANICKAM.  
66, N C.P. Kanniah Street,  
Rasipuram –637 408, Tamilnadu

Engineering Qualifications

: BE (Civil), MIE., FIV.

Number of years of experience and nature there of : More than 40 years in Civil Engineering field.

APPROVALS:

- i). Registered Valuer for Income-Tax, wealth Tax of Govt. of India, Regn.No.CI/205 / 91.
- ii). Collectorate panel engineer class 1A – R Dis 24740 / 2007 / C2 dt. 01.08.2007
- iii). Chartered Civil Engineer M / 058632/8.
- iv). Approved Valuer F 6047 dt : 17.11.1995.
- v). Approved valuer for LIC, Indian Bank, SCCB, Corporation bank, TIIC etc.
- vi). Registered Contractor Class I in PWD, TWAD Board, TNCSC etc.
- vii). Competent person under factories act.

.....

B/11



**STATEMENT TO ACCOMPANY**  
**THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

1	Location of the building – Door Number, Street and name of the place	SRV Public School, T.S.no: 30/3,30/2B2,29/5, Jahir Hussain salai, Salem road, Rasipuram municipal limit, Namakkal ( Dt).
2	Age of Building	1.Main Block: (i)Ground floor = 14 years (ii)First floor = 14 years (iii)Second floor = 14 years (iv)Head room = 14 years
3	The value of the Building at the current rates	1. Main Block: (i)Ground floor = ₹. 1,00,00,000/- (ii)First floor = ₹. 95,00,000/- (iii)Second floor = ₹. 1,00,00,000/- (iv)Head room = ₹. 1,60,000/-
4	Number of storeys	G+2
5	Short description of structures – Steel – RCC framed or load bearing masonry	R.C.C framed structure
6	Purpose for which the buildings is certified for use	School purpose / proposed for CBSE
7	The period for which the building will be structurally sound	Three years (01.06.2021 to 31.05.2024)
8	Number of persons to be accommodated	School: Students : 700 nos Warden : 30+5 nos
9	Remarks	-----

*N. Manickam*  
41574

Signature of the Engineer

**N.MANICKAM B.E,MIE,FIV.,**

DIST. PANEL ENGINEER CLASS - IA  
(Reg No. 24740/2007/C2 dt 01.08.2007 Collectorate, Namakkal)  
Chartered Civil Engineer & Valuer  
66 C.P.Kannaiah street,  
Rasipuram - 637408, Namakkal.


9/11

**FORM - E**

*(Form of report to be made to the Competent authority by inspecting authorities or officers appointed under other Acts under section 28 of the Tamil Nadu Public Buildings (Licensing) Act, 1965 (Tamil Nadu Act XIII of 1965) (Tamil Nadu Act XIII of 1965) referred to in rule 7 of the Tamil Nadu Public Buildings (Licensing) Rules, 1966)*

1	Name and designation of inspecting authority or officer appointed or having jurisdiction under any other Act or law	: N.MANICKAM. BE, MIE, FIV., DISTRICT PANEL ENGINEER CLASS IA, Thangam Associates, 66,C.P Kannaiah street, Rasipuram-637408, Namakkal (Dt).
2	Location of the building inspected (Door number, Street number, Name of place i.e., Municipal Corporation / Municipality / Panchayat or Panchayat Union / Township / Cantonment)	: SRV Public School, T.S.no: 30/3, 30/2B2,29/5, Jahir Hussain salai, Salem road, Rasipuram municipal limit, Namakkal ( Dt).
3	Date of inspection	: 01.05.2021
4	Purpose for which the building is used	: School purpose / proposed for C3SE
5	Nature of defects noticed	: No defects
6	Suggestion for rectifying defects	: Periodical maintenance to be done.
7	If in a dangerous condition, immediate steps recommended to be taken	: Not in dangerous condition, but periodical maintenance to be carried out .

Dated : 04.05.2021

  
41572  
Signature of inspecting authority

Or officer appointed or having jurisdiction

N.MANICKAM, B.E., MIE., FIV.  
Chartered Civil Engineer / Valuer  
District Panel Engineer - Class IA  
Approved Valuer for Benis  
66, C.P. Kannaiah Street,  
Rasipuram - 637 408, Namakkal (Dt)  
Cell : 98427 34147

10 / 11



**PROCEEDING OF THE DISTRICT COLLECTOR, NAMAKKAL**

**Present: Thiru. G. Sundaramurthi, J.A.S.,**

**R.Dis.24740/2007/(C2)**

**Dated: 01-08-2007**

Sub: TamilNadu Public Buildings (Licensing) Act 1965 - Namakkal District - Inclusion of the name of Thiru.N. Manickam in the panel of private practicing Engineers under class I-A (One-A) category in Namakkal District - Approval - Regarding.


Ref: 1. Application of N. Manickam, dt.27.4.02

2. This Office Roc.1191/05(C2), Dated:24.7.06.


3. Chennai Chief Engineer (General) Public Works Department, Letter No.AEE/T1/JE/42855/06 dt. 31.5.07

**Order:**


In accordance with the instructions issued by the Chief Engineer (General) Public Works Department, Chennai in the reference third cited, the name of Thiru.N.Maickam, B.E., No.66, C.P. Kannaiah Street, Rasipuram Town and Taluk and Namakkal District is included under the category of Class - I A (One A) category (The value of Buildings work costing more than Rs.30.00 Lakhs) for the purpose of issuing structural soundness certificate for public buildings in Namakkal District under the purview of the Tamil Nadu Public Buildings Licensing Act 1965.

  
District Collector,  
Namakkal.

To  
Thiru. N. Manickam, B.E.,  
No.66, C.P. Kannaiah Street,  
Rasipuram Town & Taluk,  
Namakkal District.

  
1.8.07

Copy to the Revenue Divisional Officer, Namakkal/Tiruchengode for information.  
Copy to Tahsildar, Namakkal/Rasipuram, Paramathi-Velur and Tiruchengode.  
Copy to "C2" for stock file/

  
SRV P:  
RASIPURAM - 637 408. Namakkal Dt.  
11/11